T12B

Temperature correction factor

Ambient air temperature, °C	Correction factor
10	1.14
20	1.07
30	1.00
40	0.91
50	0.82

T12C

Conductor insulation rating correction factor

Insulated conductor temperature rating, °C	Correction factor
60	0.75
75	0.885
90	1.00