T29

Rating or setting of overcurrent devices for the protection of motor branch circuits

Type of motor	Full load current, %		
	Maximum fuse rating		Mazimum setting inverse-time circuit
	Time-delay fuses*	Non-time-delay	
Alternating current			
Single-phase all types	175	300	250
Squirrel-cage and synchronous			
Full-voltage, resistor and reactor starting	175	300	250
Auto-transformer and star delta starting			
Not more than 30A	175	250	200
More than 30A	175	200	200
Wound rotor	150	150	150
Direct current	150	150	150

* Includes time-delay "D" fuses referred to in Rule 14-200.